


## DECLARATION ON FRENCH VOC REGULATION DEVL 1104875A

In compliance with the French VOC Regulation DEVL 1104875A, BN declares hereby that their wallcovering products are tested and have their correct emission label.

Emissions have been tested according to the requirements of the regulation on the labelling of construction or wall or floor coating and paints and varnishes on emissions of volatile organic compounds, based on French regulation as published on 25 March 2011 (décret DEVL1101903D) and on 13 May 2011 (arrête DEVL 1104875A). The preparation of the samples, the tests and evaluations has been made according to the requirements of the standards ISO 16000 -9, -6 and -3 in their latest versions.

The results of tests in accordance with the recommendations of the regulation can be summarized as follows: sample material fulfills the requirements for class "A+" after 28 days.



*\*Information sur le niveau d'émission de substances volatiles dans l'air intérieur, présentant un risque de toxicité par inhalation, sur une échelle de classe allant de A + (très faibles émissions) à C (fortes émissions).*

Signature: R. H. Cohen

Title: Manager Product & Process Development

### References:

MAIC-2012-2690: ISO 16000 Wallcovering  $610 \pm 50$  gr/m<sup>2</sup> : TVOC(28d) = 256  $\mu$ g/m<sup>3</sup> = A+  
MAIC-2012-2339: ISO 16000 Wallcovering  $450 \pm 50$  gr/m<sup>2</sup> : TVOC(28d) = 501  $\mu$ g/m<sup>3</sup> = A+  
MAIC-2012-0508: ISO 16000 Wallcovering  $215 \pm 20$  gr/m<sup>2</sup> : TVOC(28d) = < 1  $\mu$ g/m<sup>3</sup> = A+

**BN Walls**  
P.O. Box 2  
1270 AA Huizen  
The Netherlands

Tel: + 31 35 524 84 39  
Mail: info@bnwalls.com  
Web: bnwalls.com